

Message

---

**From:** Colletti, John [/O=EXCHANGELABS/OU=EXCHANGE ADMINISTRATIVE GROUP (FYDIBOHF23SPDLT)/CN=RECIPIENTS/CN=9591FDFA5D8049E1ACAF8B441D875ED7-JCOLLETT]  
**Sent:** 11/14/2013 9:10:49 PM  
**To:** Cecile McRoy [brwwtp@badriver-nsn.gov]  
**Subject:** RE: Mercury testing

Hi Cecile,

For the Bad River WWTP, The permit requires mercury testing for influent and effluent in January, April, July and October. For the ponds, The influent should be tested in the same months as the WWTP. The effluent of the ponds only needs to be tested once per discharge event. So to answer your question, yes, you are correct.

John

---

**From:** Cecile McRoy [mailto:brwwtp@badriver-nsn.gov]  
**Sent:** Thursday, November 14, 2013 11:48 AM  
**To:** Colletti, John  
**Subject:** Mercury testing

Hello John,

We have received the new permits in the mail, after reading these, am I correct in believing that we need to start mercury testing in the first quarter of 2014?

Thanks  
Cecile